

CALORIS™
Thermal Process Technology

Created By: TRR
Date Created: 10/23/2019

Tag Number	Description	Installed HP	Voltage/Freq/Phase	Motor Starter FVNR or VFD	Notes
EVAPORATOR SYSTEM:					
PP01	Feed Pump	3	575/60/3	VFD	For Construction
PP02	Recirculation Pump	100	575/60/3	VFD	For Construction
PP03	Product Discharge Pump	3	575/60/3	VFD	For Construction
PP04	Process Condensate Discharge Pump	2	575/60/3	VFD	For Construction
MVC01	Mechanical Vapor Compressor	150	575/60/3	VFD	For Construction
	Compressor Enclosure Venting Fan	<1	120/60/1	NO	For Construction
Total HP		258			
Total KW		192			

- 1)
- 2)